

# PURWATER

WATER RECOVERY SYSTEMS

NEWWAVE  
INDUSTRIES

## 200-5M12OX Series (60GPM) Features



- ◆ VFD Driven Continuous Duty Motor
- ◆ Self Priming Pump
- ◆ High Efficiency Cyclonic Separators
- ◆ 5 Micron Water Output
- ◆ 12 Gram Ozone
- ◆ Fiberglass & Stainless Steel Frame
- ◆ Control Signal Activation
- ◆ Automatic Fresh Water Bypass

Specifications	200-5M12OX Series (60 GPM)
<b>Water Requirements</b>	
<b>PVC</b>	(2) 2" PVC Suction lines, one for use and one for spare, to come up from settling tanks to the right of the recirculation with 2" PVC full flapper check valves at end, 2" unions above water line. (1) 2" line out to the wash manifold. (1) 1" Line to return to the second chamber of the first reclaim tank for ozone. (1) 2" freshwater line (40PSI) to the right of the system four feet up from the bottom of the floor. (1) 1" Line to return to the catch basin for the underflow of the PurWater succession filters.
<b>Reclaim Maximum Output</b>	60 GPM
<b>Reclaim Pump</b>	5 HP - Amp draw at (208/230 Volt = 13 ) / 5 HP - Amp draw at (460/480 Volt = 6.1)
<b>Pump Voltage</b>	208-230 Volts or 460-480 Volts (depending on site specifications)
<b>Dimensions</b>	48" Wide X 58" Tall X 16" Deep
<b>Net Weight</b>	700 Lbs. (including crate)
<b>Electrical Requirements</b>	
<b>Reclaim Pump and VFD</b>	(1) 208/230 Volt 30 Amp or 460/480 Volt 20 Amp Three phase circuits to be hard wired 5 feet up from the floor to the right of the system.
<b>Control Voltage for (PLC) Logic Controller and Ozone</b>	(1) 120 Volt 20 Amp Single phase
<b>Compressed Air Requirement for Ozone</b>	80 PSIG- (125 PSIG) 13.5 SCFM Continuous Demand
<b>Conduit</b>	(1) 1" Conduit from reclaim equipment control box to front of the last tank (for floats). (1) .5" Conduit from each carwash equipment control box to send a control voltage signal to PurWaters repressurization power box. Control wiring from carwash controller (110V is default, 110vac, 24vac and 24vdc avail.) to be wired into control box on frame.
<b>Tank Configuration Recommendation</b>	Triple tank configuration